



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2002010307005856

NAME AND ADDRESS OF THE APPLICANT

ZHEJIANG CHINT ELECTRICS CO., LTD
No. 1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang
Province

NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG CHINT ELECTRICS CO., LTD
No. 1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang
Province

NAME AND ADDRESS OF THE FACTORY

Zhejiang CHINT Electrics Co., Ltd.
No. 1318, Binhai No. 2 Avenue, Economic and Technical Development Zone,
Wenzhou City, Zhejiang Province, P.R. China

NAME, MODEL AND SPECIFICATION

MOULDED CASE CIRCUIT BREAKER

NM1-630S/H/R; Ue:AC400V/690V; In:400A, 500A, 630A; Thermal Magnetic Over-
current Release; Ics: Type S:25kA/400V, 5kA/690V; Type
H:32.5kA/400V, 5kA/690V; Type R:50kA/400V, 10kA/690V; Icu: Type
S:50kA/400V, 10kA/690V; Type H:65kA/400V, 10kA/690V; Type
R:100kA/400V, 20kA/690V; Tripping Class:10; Utilization
Category:A; 3P, 4P; Attached Auxiliary Contacts:AC-15; Ue/Ie:AC400V/0.4A; DC-
13; Ue/Ie:DC230V/0.2A;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification (REF
NO. CNCA-C03-02:2014).

Date of issue: Nov. 03, 2015 Date of expiry: Nov. 03, 2020

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jun. 26, 2002

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 1260489



中国国家强制性产品认证证书

证书编号: 2002010307005856

委托人名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产者(制造商)名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称、地址

浙江正泰电器股份有限公司
浙江省温州经济开发区滨海二道1318号

产品名称和系列、规格、型号

塑料外壳式断路器

NM1-630S/H/R; Ue:AC400V/690V; In:400A, 500A, 630A; 过电流脱扣器类型:热磁式; Ics:S型:25kA/400V, 5kA/690V; H型:32.5kA/400V, 5kA/690V; R型:50kA/400V, 10kA/690V; Icu:S型:50kA/400V, 10kA/690V; H型:65kA/400V, 10kA/690V; R型:100kA/400V, 20kA/690V; 脱扣级别:10; 使用类别:A类; 3P, 4P; 配用的辅助触头:AC-15:Ue/Ie:AC400V/0.4A; DC-13:Ue/Ie:DC230V/0.2A;

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2015年11月03日

有效期至: 2020年11月03日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2002年06月26日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1260489