



中国国家强制性产品认证证书

证书编号: 2002010307005874

委托人名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产者(制造商)名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称、地址

浙江正泰电器股份有限公司
浙江省温州经济开发区滨海二道1318号

产品名称和系列、规格、型号

剩余电流动作断路器
DZ20L-400; 参数及型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2018年12月28日 有效期至: 2020年11月01日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2002年06月26日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2002010307005874

NAME AND ADDRESS OF THE APPLICANT

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang
Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang
Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang CHINT Electric Co., Ltd.
No.1318, Binhai No.2 Avenue, Economic and Technical Development Zone, Wenzhou City,
Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit Breaker
DZ20L-400; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Dec.28,2018

Valid until: Nov.01,2020

The validity of the certificate is subject to positive result of the regular follow up
inspection by issuing certification body until the expiry date.

Date of original issued: Jun.26,2002

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

证书编号: 2002010307005874

第 1 页 共 2 页

纸 号: 2200360

DZ20L-400;

U_i : 800V; U_{imp} : 8kV;

U_e : AC380V;

I_n : 200A, 250A, 315A, 350A, 400A;

过电流脱扣器类型: 热磁式、电磁式;

使用类别: A 类;

脱扣级别: 20;

I_{cs} : 10kA; I_{cu} : 20kA;

$I_{\Delta m}$: 5kA;

$I_{\Delta n}$: 单档 (非延时型): 0.03A, 0.05A, 0.1A, 0.2A, 0.3A, 0.5A;

单档 (延时型): 0.05A, 0.1A, 0.2A, 0.3A, 0.5A;

三档可调 (非延时型): 0.05A/0.1A/0.2A, 0.1A/0.2A/0.3A, 0.2A/0.3A/0.5A;

额定剩余动作类型: AC 型;

剩余电流脱扣器类型: 电子式;

极数: 3P+N (3 个保护极, N 极不可开闭), 4P (3 个保护极, N 极可开闭); 不适用于隔离用;

配用的辅助触头: I_{th} : 6A; 2NO2NC;

AC-15: U_e/I_e : AC380V/3A; DC-13: U_e/I_e : DC220V/0.2A;

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2002010307005874

纸 号: 2200360

型号的解释:

DZ 20 L - 400 / □ □ □ □ □ □ □
(1) (2) (3) (4) (5) (6) (7) (8) (9) (10) (11)

- (1)塑料外壳式断路器
- (2)设计代号
- (3)电子式剩余电流动作保护
- (4)壳架等级额定电流
- (5)极数: 四极 (代号 4); 三极四线 (代号 3N)
- (6)脱扣器型式及附件代号 (见表 1)
- (7)用途代号: 配电保护用无代号; 电动机保护用 (代号 2)
- (8)剩余电流的延时功能代号: 非延时型无代号, 延时型代号 Y
- (9)缺相保护功能代号: 不带缺相保护无代号, 带缺相保护代号 U
- (10)剩余电流脱扣器型式代号 (见注 1)
- (11)派生代号: 常规产品无代号, 透明盖 (T)

注 1:

按剩余电流脱扣器型式分:

当剩余电流达到或超过整定值时脱扣 (无代号) — 不带剩余电流报警模块;

当剩余电流达到或超过整定值时只报警不脱扣 (代号 J) — 带剩余电流报警模块;

表 1 脱扣器型式及附件代号

附件名称	脱扣器型式及附件代号	
	电磁式脱扣器	热磁脱扣器
无附件	200	300
分励脱扣器	210	310
辅助触头	220	320
欠压脱扣器	230	330
分励脱扣器、辅助触头	240	340
欠电压脱扣器、辅助触头	370	370

注: 240、340、270、370 只适用于四极剩余电流动作断路器。

注: 此附录与证书同时使用时有效。



主 任:

陆梅



中国质量认证中心