



中国国家强制性产品认证证书

证书编号：2002010307005866

委托人名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产者（制造商）名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称、地址

浙江正泰电器股份有限公司
浙江省温州经济开发区滨海二道1318号

产品名称和系列、规格、型号

剩余电流动作断路器（漏电断路器）

DZ15LE-40;

Ue:AC220V(2P),AC380V(3P,3P+N,4P);In:6A,10A,16A,20A,25A,32A,40A;I Δ n:0.03A,0.05A,0.075A,0.1A;AC型;过电流脱扣器类型:液压电磁式;使用类别:A类;漏电脱扣器类型:电子式;Icu:3kA;Ics:1.5kA;I Δ m:1kA;脱扣级别:10;2P,3P,3P+N,4P;型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2019年01月16日 有效期至：2020年12月31日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2002年06月26日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2002010307005866

NAME AND ADDRESS OF THE APPLICANT

ZHEJIANG CHINT ELECTRICS CO., LTD

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province

NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG CHINT ELECTRICS CO., LTD

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province

NAME AND ADDRESS OF THE FACTORY

Zhejiang CHINT Electrics Co.,Ltd.

No.1318, Binhai No.2 Avenue, Economic and Technical Development Zone, Wenzhou City, Zhejiang Province, P.R. China

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit Breaker

DZ15LE-40; Ue:AC220V(2P),AC380V(3P,3P+N,4P);In:6A,10A,16A,20A,25A,32A,40A;IΔn:0.03A,0.05A,0.075A,0.1 A;Type AC;Electromagnetic Hydraulic Over-current Release;Utilization Category:A;Electronic Residual Current Tripping Unit;Icu:3kA;Ics:1.5kA;IΔm:1kA;Tripping Class:10;2P,3P,3P+N,4P;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jan.16,2019

Valid until: Dec.31,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jun.26,2002

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

证书编号: 2002010307005866

第 1 页 共 1 页

纸号: 2170624

型号的解释:

DZ 15 LE - 40 / □ 90 □ □ □
 (1) (2) (3) (4) (5) (6) (7) (8) (9)

- (1)塑料外壳式断路器
- (2)设计代号
- (3)特殊派生代号(电子式剩余电流动作断路器)
- (4)壳架等级额定电流
- (5)极数(2.二极; 3.三极; 4.四极)
- (6)液压式电磁脱扣器
- (7)保护种类(1.配电保护用; 2.电动机保护用)
- (8)四极剩余电流动作断路器的N极类型*
- (9)派生代号: 常规产品无代号; 透明盖产品用T表示

注*: A型N极不安装过电流脱扣器元件,且N极始终接通,不与其他三极一起分合(A可省略不标);
 B型N极不安装过电流脱扣器元件,且与其他三极一起分合。

注: 此附录与证书同时使用时有效。



主任: 陆杨



中国质量认证中心