



# 中国国家强制性产品认证证书

证书编号：2017010307028859

### 委托人名称、地址

浙江正泰网络技术有限公司  
杭州市滨江区滨安路1335号1幢B栋3楼302室

### 生产者（制造商）名称、地址

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

### 生产企业名称、地址

浙江正泰电器股份有限公司  
浙江省温州经济开发区滨海二道1318号

### 产品名称和系列、规格、型号

剩余电流动作断路器(漏电断路器)

DZ15LE-100E;Ue:AC220V/380V;In:10A,16A,20A,25A,32A,40A,50A,63A,80A,100A;IΔn:0.03A,0.05A,0.075A,0.1A,0.3A; AC型;过电流脱扣器类型:液压电磁式;使用类别:A类;剩余电流脱扣器类型:电子式;脱扣级别:10;Icu:5kA;Ics:2.5kA; IΔm:1.5kA;2P,3P,3P+N,4P;详情见附件

### 产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2017年12月08日 有效期至：2020年10月19日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：



## 中国质量认证中心





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017010307028859

## NAME AND ADDRESS OF THE APPLICANT

ZheJiang CHINT Network Technology Co.,Ltd.  
Room 302,3nd Floor,Block B, 1st Building,No.1335 BinAn Rd,Binjiang Dist,Hangzhou,P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG CHINT ELECTRICS Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province,  
P.R.China

## NAME AND ADDRESS OF THE FACTORY

ZHEJIANG CHINT ELECTRICS Co., Ltd.  
No.1318, Binhai No.2 Avenue, Economic and TechnicalDevelopment Zone, Wenzhou City, Zhejiang  
Province, P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit Breaker

DZ15LE-100E;Ue:AC220V/380V;In:10A,16A,20A,25A,32A,40A,50A,63A,80A,100A;IΔn:0.03A,0.05A,0.075A,0.1A,0.3A; Type AC;Electromagnetic Hydraulic Over-current Release;Utilization Category:A;Electronic Residual Current Tripping Unit;Tripping Class:10;Icu:5kA;Ics:2.5kA;IΔm:1.5kA;2P,3P,3P+N,4P

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Dec.08,2017

Valid until: Oct.19,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE





# 中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号：2017010307028859

纸 号：1850826

型号解释：

DZ 15 LE -100 E/ □ 90/ □ □ □  
(1) (2) (3) (4) (5) (6) (7) (8) (9) (10)

(1)塑料外壳式断路器

(2)设计代号

(3)特殊派生代号(电子式剩余电流动作断路器)

(4)壳架等级额定电流

(5)电商专供

(6)极数(2,二级; 3,三级;4,四极)

(7) 液压式电磁脱扣器

(8)保护种类 (1.配电保护用; 2.电动机保护用)

(9)四极剩余电流动作断路器的N极类型\*

(10)派生代号: 常规产品无代号; 透明盖产品用T表示

注\*: A型N极不安装过电流脱扣器元件,且N极始终接通,不与其它三极一起合分(A可省略不写标);

B型N极不安装过电流脱扣器元件,且与其余三极一起合分。

注：此附录与证书同时使用时有效。



主 任：



## 中国质量认证中心