



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016010307888048

NAME AND ADDRESS OF THE APPLICANT

ZHEJIANG CHINT ELECTRICS CO., LTD.

No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG CHINT ELECTRICS CO., LTD.

No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

ZHEJIANG CHINT ELECTRICS CO., LTD.

No.1318, Binhai No.2 Avenue, Economic and Technical Development Zone, Wenzhou City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Residual current operated circuit breaker

NM2LC-630、NM2LC-630/M、NM2LC-630/M/S; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Nov.28,2017

Valid until: Jun.20,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jul.27,2016

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666

Q 1862056



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2016010307888048

纸 号: 1862056

NM2LC-630、NM2LC-630/M、NM2LC-630/M/S Ue: AC400V; Ui: 800V; In: 630A (315A、350A、400A、500A、630A 可调); Uimp: 8kV; 过电流脱扣器类型: 电子式; NM2LC-630 (H 型): Icu: 85kA; Ics: 65kA; NM2LC-630/M、NM2LC-630/M/S (M 型): Icu: 65kA; Ics: 42kA; Icw: 8kA/1s; 剩余电流脱扣器型式: 电子式; $I\Delta n$: 100mA/200mA/300mA/500mA/800mA/1000mA(可调)/AC 型; 使用类别: B 类; NM2LC-630 (H 型): $I\Delta m$: 21.5kA; NM2LC-630/M、NM2LC-630/M/S (M 型): $I\Delta m$: 16.5kA; 自动重合闸时间: 20s~60s; 极数: 3P+N(三个保护极, 带不可开断中性线, 不适用于隔离用)

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2016010307888048

委托人名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产者(制造商)名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称、地址

浙江正泰电器股份有限公司
浙江省温州经济开发区滨海二道1318号

产品名称和系列、规格、型号

剩余电流保护断路器
NM2LC-630、NM2LC-630/M、NM2LC-630/M/S;详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2017年11月28日 有效期至: 2021年06月20日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年07月27日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心