



# 中国国家强制性产品认证证书

证书编号：2015010307829325

委托人名称、地址

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产者（制造商）名称、地址

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称、地址

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

产品名称和系列、规格、型号

剩余电流动作断路器  
NXBLE-63, NXBLG-63, NXBLE-63H, NXBLE-63ZB; 参数详见附件

产品标准和技术要求

GB/T16917.1-2014, GB/T16917.22-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2018年12月26日 有效期至：2020年12月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2015年12月16日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：

陆梅



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

**CERTIFICATE NO.: 2015010307829325**

## **NAME AND ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electric Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang  
Province, P.R.China

## **NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang CHINT Electric Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang  
Province, P.R.China

## **NAME AND ADDRESS OF THE FACTORY**

Zhejiang CHINT Electric Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province,  
P.R.China

## **PRODUCT NAME, MODEL AND SPECIFICATION**

Residual Current Operated Circuit-breakers With Integral Overcurrent Protection  
NXBLE-63, NXBLG-63, NXBLE-63H, NXBLE-63ZB; See the Appendix

## **THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T16917.1-2014, GB/T16917.22-2008

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

**Valid from:** Dec.26,2018

**Valid until:** Dec.16,2020

The validity of the certificate is subject to positive result of the regular follow up  
inspection by issuing certification body until the expiry date.

Date of original issued: Dec.16,2015

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Lu Mei



## **CHINA QUALITY CERTIFICATION CENTRE**



# 中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2015010307829325

纸 号: 2206058

NXBLE-63, NXBLG-63, NXBLE-63H, NXBLE-63ZB;

Ui: 500V; Uimp: 4kV;

Ue: AC220V/230V/240V (1P+N, 2P); AC380V/400V/415V (3P, 3P+N, 4P);

In: 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

瞬时脱扣特性: NXBLE-63, NXBLE-63H, NXBLE-63ZB: B 型, C 型, D 型;

NXBLG-63: C 型;

$I \Delta n$ : NXBLE-63, NXBLE-63H: 0.01A, 0.03A, 0.05A, 0.075A, 0.1A, 0.3A/AC 型;

NXBLE-63, NXBLE-63H: 0.03A, 0.1A, 0.3A/A 型;

NXBLG-63: 0.03A/AC 型;

NXBLE-63ZB: 0.03A/AC 型;

电子式漏电脱扣器;  $I \Delta m$ : 630A;

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



## 中国质量认证中心



# 中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号：2015010307829325

纸 号：2206058

Ics:6000A(NXBLE-63,NXBLG-63,NXBLE-63ZB);7500A(NXBLE-63H);

Icn:6000A(NXBLE-63,NXBLG-63,NXBLE-63ZB);10000A(NXBLE-63H);

极数：NXBLE-63:2P, 3P,4P,1P+N(1 个保护极，N 极常通),3P+N (3 个保护极，N 极常通);

NXBLG-63:2P,1P+N (1 个保护极，N 极常通);

NXBLE-63H:2P;

NXBLE-63ZB:1P+N (1 个保护极，N 极常通)、2P;

1P+N,3P+N 不适用隔离，其余均适用于隔离。

注：此附录与证书同时使用时有效。



主 任：

陆 楠



## 中国质量认证中心