



中国国家强制性产品认证证书

证书编号: 2015010307829323

委托人名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产者(制造商)名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

产品名称和系列、规格、型号

剩余电流动作断路器
NXBLE-32, NXBLG-32, NXBLE-32H, NXBLE-32ZB; 参数详见附件

产品标准和技术要求

GB/T16917.1-2014, GB/T16917.22-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2018年12月26日 有效期至: 2020年12月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2015年12月16日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2015010307829323

NAME AND ADDRESS OF THE APPLICANT

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang
Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang
Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province,
P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-breakers With Integral Overcurrent Protection
NXBLE-32, NXBLG-32, NXBLE-32H, NXBLE-32ZB; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T16917.1-2014, GB/T16917.22-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Dec.26,2018

Valid until: Dec.16,2020

The validity of the certificate is subject to positive result of the regular follow up
inspection by issuing certification body until the expiry date.

Date of original issued: Dec.16,2015

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2015010307829323

纸 号: 2206057

NXBLE-32, NXBLG-32, NXBLE-32H, NXBLE-32ZB;

Uimp:4kV; Ui:500V;

Ue: AC220V/230V/240V (1P+N,2P); AC380V/400V/415V (3P,3P+N,4P);

In: 6A,10A,16A,20A,25A,32A;

瞬时脱扣特性: NXBLE-32, NXBLE-32H, NXBLE-32ZB: B, C, D 型;

NXBLG-32: C 型;

$I \Delta n$: NXBLE-32, NXBLE-32H: 0.01A, 0.03A, 0.05A, 0.075A, 0.1A, 0.3A/AC 型;

NXBLG-32, NXBLE-32ZB: 0.03A/AC 型;

额定剩余动作类型: AC 型;

电子式漏电脱扣器; $I \Delta m$: 630A;

I_{cn} : 6000A (NXBLE-32, NXBLG-32, NXBLE-32ZB); 10000A (NXBLE-32H);

I_{cs} : 6000A (NXBLE-32, NXBLG-32, NXBLE-32ZB); 7500A (NXBLE-32H);

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2015010307829323

纸 号: 2206057

极数: NXBLE-32:2P, 3P, 4P, 1P+N (1 个保护极, N 极常通), 3P+N (3 个保护极, N 极常通);

NXBLG-32:2P, 1P+N (1 个保护极, N 极常通);

NXBLE-32H:2P;

NXBLE-32ZB:1P+N (1 个保护极, N 极常通), 2P;

1P+N、3P+N 不适用隔离, 其余均适用于隔离.

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心